

Interconnect Challenges in the Developing World's Distributed Generation Infancy



MAVEN POWER LLC
POWER GENERATION EXPERTS

David C. Oehl, P.E.
President



Overview

- Introduction
- Project Background
- DG Plant Operation
- Challenges
 - Interconnection
 - Operational
 - Utility/Regulatory
- Results & Takeaways


Introduction

- Onsite & Distributed Generation
- Thermal Power Generation
- Engineering to Turn-key
 - Specialize in custom apps
 - Single source for integration
 - International expertise, challenging locations



Introduction

- Equipment
- Fuel systems
- Electrical & distribution
- Design & integration
- Project management
- O & M
- Automation






Project Background

- 2.5MWe On-site Generation
- Natural gas-fired
- Utility new to DG
- Integration effort
- Industrial, general use feeder

One Line Diagram



2.5MWe Onsite Generation



15kV Switchgear



MAVEN POWER₆
POWER GENERATION EXPERTS



SG-1



SG-2

Automatic Source Transfer Control



Plant Operation

- Grid parallel w/ power import
- Automatic source transfer switching
- Generator operation at base load
- Islanding operation upon loss of normal supply



Challenges

- Grid Instability
- Voltage Sag
- 5% drop for more than 5 cycles
- 15-20% of nominal not uncommon
- Resulting reverse power condition
- Load shedding
- Recloser Issues




Reverse Power

- Trips up to six times daily
- Anti-islanding required a main breaker trip (SG-1 or SG-2)
- Production interruptions
- Nominal phase current = 130A

SG2 Fault Recorder Data for Reverse Power (32R) Events

Record	Date	Time	Duration (cycles)	Current (A)
1	21-Jan-06	5:34:07 AM	6.24	22
3	21-Jan-06	7:58:32 AM	3.46	40
5	21-Jan-06	10:12:55 AM	5.46	300
7	22-Jan-06	7:47:34 AM	6.21	45
12	22-Jan-06	9:23:37 PM	2.96	20
14	23-Jan-06	12:51:51 PM	6.21	45
16	24-Jan-06	4:34:39 AM	2.46	30
18	24-Jan-06	8:21:52 AM	2.96	15
		<i>Average</i>	4.50	cycles
		<i>Max</i>	6.24	cycles

Reverse Power-Typical Observed Condition






Recloser Issues

- No recloser lockout available
- Set to reclose automatically after 500mS
- No accommodation for 2nd source (DG)
- No effective way to distinguish between OCR operation and voltage sag-mandatory trip
- 32R protective function required
- 67P possible with recloser lockout

Recloser Timing

Typical Time Dynamics for Voltage Sags, Reverse Power and Recloser Functions at SG2





Utility Issues

- New to DG/Onsite Power
- Low internal empowerment, low motivation for DG support
- Proposal to install 25 (synch check) or 27 (undervoltage) monitoring system
- Regulatory body (FERC) limited authority



Takeaways

- Breaker arrangement critical
- Ability to 'cross trip' on voltage sag or reverse power condition
- Problem was transparent to end user (Maven Power's Customer)
- Full solution a combinations of reverse power monitoring (67P) with recloser lockout.
- Simple, economical improvements by utility
 - Regular transformer maintenance
 - Line inspection & cleaning (rain)

Questions?



David C. Oehl, P.E
President
MAVEN POWER, LLC
705 Boardwalk Drive
Suite 414
Ponte Vedra, FL 32082
(904) 514-8289 Tel
(904) 395-9999 Fax
doehl@mavenpower.com
www.mavenpower.com